
133E4610
TO SHEET 4 ZONE D-5
TO SHEET 4 ZONE C-2
TO SHEET 4 ZONE D-3
0 - 25 PSID [0 - 1.7 BARD]
PDI QQ-21
PDS 63QQ-21
PT 96QQ-1
LDHX-1
LF3-1
OIL VENT
VENT (TYP.)
CLEAN SIDE DRAIN (TYP)
LOW POINT DRAIN
Ø 0.125 [3.2 MM] ORIFICE
PDI QQ-22
PDS 63QQ-22
PT 96QQ-2
LDHX-2
LF3-2
PS 63QA-1B
PS 63QA-1A
0 - 200 PSIG [0 - 13.8 BARG]
PI QS-3
VTA LO19 SEE NOTE 10
TO MU OK19 TIMPOL
TO MU 0434 HYDRAULIC SUPPLY
Ø 2.77 [70.4 MM] ORIFICE SEE NOTE 9
F0-7
Ø 1.98 [50.3 MM] ORIFICE
F0-3
FILTERED OIL SAMPLE
VPR2-11
PDI QQ-25
PDS 63QQ-25
LF3-5
PT 96QG-1
0 - 60 PSIG [0 - 4.14 BARG]
PI QA-1A
20 - 240°F [-5 - 115°C]
TE LT-TH-1
TI QA-1
TE LT-TH-2
TE LT-TH-3
TO SHEET 4 ZONE D-4
FROM SHEET 4 ZONE D-3
FROM SHEET 4 ZONE D-5
FROM SHEET 4 ZONE C-2
TO SHEET 4 ZONE C-6
TO SHEET 4 ZONE C-8
TO SHEET 4 ZONE B-6
PS 63QE-1
PI QA-1
PI QA-2
PI QE-1
PI QS-1
SEE NOTE 5
SEE NOTE 8
FB1-1
FB2-1
88QV-1A 23QV-2A
88QV-1S 23QV-2S
LF3-3
0 - 10 IN H2O [0 - 254 MM H2O]
PDI QV-1
PDS 63QV-1
VTA
-10 - 6 IN [-254 - 152 MM]
LI QH-1
LSH 71QH-1
LSL 71QL-2
LSL 71QL-1
OIL TANK SEE NOTES 4, 6 & 7
19.5 [495.3 MM] TO NORMAL OIL LEVEL SEE NOTE 3
OIL LEVEL
LT 95QL-1
TE LT-OT-3
TE LT-OT-4
BLOWOUT PANEL 8 (QTY 12)
88QA-1 23QA-1
88QA-2 23QA-2
88QE-1
88QS-1 23QS-1
PQ1-1
PQ1-2
PQ2-1
PQ3-1
Ø .25 [6.4 MM] SIPHON BREAK AT LOW LEVEL ALARM SET POINT
SLOPE
23QT-1
23QT-2
23QT-3
TI QL-1
ACCESSORY MODULE LUBE OIL COMPARTMENT A160
GE Energy
SENTHIL PITCHAI
BENITO CORASANITI
133E4610
2 of 4